

APPENDIX III



Daily Log: Wednesday 2/28/2024



Daily Log Completed

The Daily Log was completed by Christopher Triana on Tue, Apr 30, 2024 at 09:13 AM EDT.

WEATHER REPORT

Temperature			Precipitation Since			Humidity				Windspeed		
Low	High	Avg	Midnight	2 Days Ago	3 Days Ago	Low	Avg	High	Dew	Avg	Max	Gust
43°F	66°F	59°F	0.37 in.	0.47 in.	0.47 in.	35%	73%	94%	50°F	9.1 mph	11 mph	27 mph

DAILY SNAPSHOT

06:00 AM	09:00 AM	12:00 PM	03:00 PM	06:00 PM	09:00 PM
No Description 61°F	No Description 62°F	No Description 65°F	No Description 63°F	No Description 62°F	No Description 52°F

OBSERVED WEATHER CONDITIONS

No.	Time Observed	Weather Delay	Sky	Temp	Average	Precipitation	Wind	Ground/Sea
1	07:55:00 AM	No						

NOTES LOG

No.	Created By	Issue?	Location	Comments
1	Christopher Triana	No		QCS Inspectors Chris Triana and Caleb Brame were on site to conduct an evaluation of the waste water treatment tanks The following items were noted:
2	Christopher Triana	No		A complete inspection was not possible, due to the fact that they were still in service. Both membrane tanks present spot coatings failure. It is unknown how much coatings failure and metal loss is present below the water line and should be fully evaluated during rehabilitation.
3	Christopher Triana	No		QCS Inc. recommends having the tanks vacuumed, high pressure water washed, and repaired utilizing patch plates and coatings touch ups with an appropriate coating material.

Notes Log's Attachments:



[20240228_100148.jpg](#)



[20240228_101226.jpg](#)




[20240228_102757.jpg](#)



[20240228_102801.jpg](#)



[20240228_102809.jpg](#)



[20240228_103025.jpg](#)



[20240228_103030.jpg](#)



[20240228_103036.jpg](#)



[20240228_103036\(0\).jpg](#)



[20240228_103040.jpg](#)